

FIRE FACT NO. 018 CHECKLIST(s) : 06

TITLE : LEVEL LANDINGS

CHECKLIST ITEM(s) : 06-09 & 06-10

REFERENCE(s) : 91-101/5-2.1.3.3

PAGE 1 of 1

Level landings must be provided to prevent tripping and falling from exterior exits in a panic or rapid evacuation situation. We recognize the problems with renovating steps and exterior concrete work. While the adopted codes are clear on the requirement for providing level landings (i.e. no variation in elevation), we will accept existing exterior landings that fall within the criteria shown in the following diagram.

